

0195

(504) 444-9365

11300  
1143CFB

8 JAN 1985

From: Commander, Atlantic Division, Naval Facilities Engineering Command  
To: Commanding General, Marine Corps Base, Camp Lejeune

Subj: TESTING OF POTABLE WATER WELLS AND WATER TREATMENT PLANT

Ref: (a) LANTNAVFACENGCEN msg 071346Z Dec 1984

Encl: (1) Reports #4, #7, #8, #10, and #12; Laboratory Analysis on Naval  
Samples by JTC Environmental Consultants, Inc.

1. Reference (a) forwarded preliminary results from testing of potable water wells and recommended additional sampling of Hadnot Point water treatment plant for volatile organics. Enclosure (1), a formal report of the sampling effort to date, is forwarded for your use. Our evaluation and recommendations will follow under separate cover.

R. D. CROWSON P.E.  
Director, Utilities, Energy and  
and Environmental Division

Copy to:  
Environmental Science and Engineering (ESE)  
P. O. Box ESE  
Gainesville, FL 32602  
Attn: Russ Bowen  
Blind Copy to:  
114  
114S  
Doc #2663A/CFB/dhs.

CLW

0000001103

Barnett  
Smith  
12/28/84

ROUTINE REPLY, ENDORSEMENT, TRANSMITTAL OR INFORMATION SHEET

OPNAV 5216/158 (Rev. 7-78)  
SN 0107-LF-052-1691

WINDOW ENVELOPE MAY BE USED  
Formerly NAVEXOS 378V

CLASSIFICATION (UNCLASSIFIED when detached from enclosures, unless otherwise indicated)

FROM (Show telephone number in addition to address)

PH (804) 444-9566

C. BARNETT, LANAVFACENGCOM 1143, NORFOLK, VA

DATE

1/8/84

SUBJECT

SERIAL OR FILE NO.

GROUNDWATER ANALYSIS, WELL 602 (QC CHECK)

TO:

REFERENCE

CG MCB Camp Lejeune  
ATTN: ASST CHIEF OF STAFF - FACILITIES  
MR. BOB ALEXANDER  
CAMP LEJEUNE, NC 28542

ENCLOSURE

J.R. REED LAB REPORT  
(ANALYSIS BY GRANGER  
ON WELL 602  
SAMPLE OF 12/13/84)

VIA:

ENDORSEMENT ON

FORWARDED  RETURNED  FOLLOW-UP, OR TRACER  REQUEST  SUBMIT  CERTIFY  MAIL  FILE

GENERAL ADMINISTRATION	CONTRACT ADMINISTRATION	PERSONNEL
FOR APPROPRIATE ACTION	NAME & LOCATION OF SUPPLIER OF SUBJECT ITEMS	REPORTED TO THIS COMMAND:
UNDER YOUR COGNIZANCE	SUBCONTRACT NO. OF SUBJECT ITEM	
<input checked="" type="checkbox"/> INFORMATION	APPROPRIATION SYMBOL, SUBHEAD, AND CHARGEABLE ACTIVITY	DETACHED FROM THIS COMMAND
APPROVAL RECOMMENDED <input type="checkbox"/> YES <input type="checkbox"/> NO	SHIPPING AT GOVERNMENT EXPENSE <input type="checkbox"/> YES <input type="checkbox"/> NO	OTHER
<input type="checkbox"/> APPROVED <input type="checkbox"/> DISAPPROVED	A CERTIFICATE, VICE BILL OF LADING	
COMMENT AND/OR CONCURRENCE	COPIES OF CHANGE ORDERS, AMENDMENT OR MODIFICATION	
CONCUR	CHANGE NOTICE TO SUPPLIER	
LOANED. RETURN BY:	STATUS OF MATERIAL ON PURCHASE DOCUMENT	
SIGN RECEIPT & RETURN		
REPLY TO THE ABOVE BY:		

REFERENCE NOT RECEIVED

SUBJECT DOCUMENT FORWARDED TO:

SUBJECT DOCUMENT RETURNED FOR:

SUBJECT DOCUMENT HAS BEEN REQUESTED, AND WILL BE FORWARDED WHEN RECEIVED

COPY OF THIS CORRESPONDENCE WITH YOUR REPLY

ENCLOSURE NOT RECEIVED

ENCLOSURE FORWARDED AS REQUESTED

ENCLOSURE RETURNED FOR CORRECTION AS INDICATED

CORRECTED ENCLOSURE AS REQUESTED

REMOVE FROM DISTRIBUTION LIST

REDUCE DISTRIBUTION AMOUNT TO:

REMARKS (Continue on reverse)

BOB - NOTE THAT BENZENE DID NOT SHOW UP HERE, ALTHOUGH JTC FOUND 250 ppb IN THEIR SAMPLE. (RAKOWSKI SUGGESTED IT MAY HAVE VOLATILIZED OFF DUE TO DELAY IN ANALYSIS; HOWEVER, LAB TO RECHECK). OTHER PARAMETERS COMPARABLE TO RESULTS OBTAINED BY JTC ESE RESULTS NOT IN YET. LETTER TO FOLLOW SOON.

SIGNATURE & TITLE

COPY TO:

(Cherry)

CLASSIFICATION (UNCLASSIFIED when detached from enclosures, unless otherwise indicated)